

PRIVATE PUMP STATION SIGNAGE REQUIREMENTS

**PRIVATE
SANITARY SEWER
PUMP STATION**

In case of emergency contact the
following numbers:

Facility Owned by:
Name: _____
Phone Number: _____

Facility Maintained by:
Name: _____
Phone Number: _____

Station Number: _____

SIGNAGE REQUIREMENTS:

- MINIMUM SIGN SIZE = 12 INCHES x 18 INCHES
- SIGN CONSTRUCTION = 0.04 GAUGE ALUMINUM OR EQUIVALENT PERFORMING MATERIALS
- OBTAIN STATION NUMBER FROM THE CITY OF COOS BAY, DEPARTMENT OF PUBLIC WORKS AND COMMUNITY DEVELOPMENT DEPARTMENT
- SIGNAGE INSTALLATION FOR PRIVATE PUMP STATIONS IS A REQUIREMENT OF COSS BAY FOG MANAGEMENT PROGRAM CODE